

# ***SaskPower***

## **Request for Proposals**

### **Environmentally Preferred Power Projects**

#### **Inquiry No. WE/301**

#### **Addendum No. 1**

---

**The following Addendum shall be attached to and form part of the Request for Proposals and Related Documents.**

1. On page 6, Section 1.3, **Purpose of the RFP**, EPP Project Parameter:

In item (c), delete the following words:

“based on the total generation capacity under average annual conditions”.

2. On page 12, Section 1.9, **EVALUATION OF PROPOSALS, Evaluation Criteria**:

Add the following section:

“k) The total generating capacity of the proposed EPP Project is 25 kW to 5 MW in size. For the purpose of selecting proposals, SaskPower will define this parameter as being any project with a NEMA Generator Rating of at least 25 kW or 27.8 kVA but not greater than 5 MW or 5.6 MVA in total for all generators connected to the SaskPower Electric System. For this purpose, connected means either connected or capable of being connected through operation of an interrupting device.”

3. On page 14, Section 2.1, **EPP PROJECT PARAMETERS AND COMMERCIAL REQUIREMENTS**, EPP Project Parameter:

In item (d), delete the following words:

“(between 25 kW to 5 MW in size) under average annual conditions”

and replace them with:

“in terms of the NEMA Generator Rating for all generators connected to the SaskPower Electric System.”.

**All other terms and conditions to remain the same.**

**You are to acknowledge receipt of this Addendum in your proposal.**

March 24, 2004