

**D10A Notes:**

- (1) *This Table provides the allowable ampacity for 90°C rated copper conductor cables containing not more than 3 current carrying conductors, or not more than 3 single copper current carrying conductors in contact, directly buried in earth.*
- (2) *Underground ampacities for a conductor temperature of 75°C may be obtained by multiplying the appropriate ampacity at 90°C conductor temperature by the derating factor 0.886.*
- (3) *See Rule 4-006 for equipment termination temperature requirements.*

**D11A Notes:**

- (1) *This Table provides the allowable ampacity for 90°C rated copper conductor cables containing not more than 3 current carrying conductors, or not more than 3 single copper current carrying conductors in contact, installed in underground raceway.*
- (2) *Underground ampacities for a conductor temperature of 75°C may be obtained by multiplying the appropriate ampacity at 90°C conductor temperature by the derating factor 0.886.*
- (3) *See Rule 4-006 for equipment termination temperature requirements.*

**D10B Notes:**

- (1) *This Table provides the allowable ampacity for 90°C rated aluminum conductor cables containing not more than 3 current carrying conductors, or not more than 3 single aluminum current carrying conductors in contact, directly buried in earth.*
- (2) *Underground ampacities for a conductor temperature of 75°C may be obtained by multiplying the appropriate ampacity at 90°C conductor temperature by the derating factor 0.886.*
- (3) *See Rule 4-006 for equipment termination temperature requirements.*

**D11B Notes:**

- (1) *This Table provides the allowable ampacity for 90°C rated aluminum conductor cables containing not more than 3 current carrying conductors, or not more than 3 single aluminum current carrying conductors in contact, installed in underground raceway.*
- (2) *Underground ampacities for a conductor temperature of 75°C may be obtained by multiplying the appropriate ampacity at 90°C conductor temperature by the derating factor 0.886.*
- (3) *See Rule 4-006 for equipment termination temperature requirements.*